


EU Declaration of Conformity

- MULTICAL® 403 2
- Kamstrup Pt500 Temperature Sensors 3
- Kamstrup Temperature Sensor 63/83 4
- Kamstrup Temperature Sensors 4

Scan the QR code to explore the
MULTICAL® 403 at [kamstrup.com](https://www.kamstrup.com)



<https://www.kamstrup.com/en-en/heat-solutions/meters-devices/meters/multical-403>

Note: In the event of inconsistency or discrepancy between the English version and any other language version, the English version shall prevail.

kamstrup

EU DECLARATION OF CONFORMITY

Kamstrup A/S
 Industrivej 28, Stilling
 DK-8660 Skanderborg
 T: +45 89 93 10 00
 F: +45 89 93 10 01
 M: kamstrup@kamstrup.com

We, Kamstrup A/S declare that this Declaration is issued under our sole responsibility and belongs to the following product: **MULTICAL® 403**, Ultrasonic Heat, Cooling and Heat/Cooling meter, type number 403XXXXXX-XXXXX (Note 1 applies), serial number XXXXXXXX/XX/25, which is in conformity with the relevant European Directives, including all consolidated versions, as marked below:

RoHS (2011/65/EU), standard: EN/IEC 63000:2018.

EMCD (2014/30/EU), standards: EN 61326-1:2013 and EN 61326-1:2021.

Applies to type numbers: 403-xxxxxx-xxx**00/10/11/20/21/22/40/42/43/66/67/81/82/83**.

MID (2014/32/EU), standards: EN 1434:2007/AC:2007, EN 1434:2015/A1:2018/A1:2019, EN 1434:2022, WELMEC 7.2:2023.

Applies for products marked with CE marking and supplementary metrology marking according to Article 21 in directive 2014/32/EU. Module B certificate number: DK-0200-MI004-037.

Notified Body, Module D certificate: FORCE Certification A/S, EU Notified Body number: 0200, Park Allé 345, DK-2605 Brøndby. Module D certificate number: DK-0200-MID-D-001.

LVD (2014/35/EU), standard: EN 61010-1:2010, EN 61010-1:2010/A1:2019 and EN 61010-1:2010/A1/AC:2019.

RED (2014/53/EU), standards: EN 300 220-2 v.3.1.1:2017, EN 301 489-1 v2.2.3:2019, EN 301 489-3 v2.1.1:2019, EN 301 511 v12.5.1, EN 301 908-1 v15.2.1, EN 301 908-13 v13.2.1, EN 62311:2020, EN 301 489-52 v1.2.1.

Applies to type numbers: 403-xxxxxx-xxx**30/31/32/33/50/51/53/56/58**.

PED (2014/68/EU), standard: EN 13480-3:2017. PS: 25 bar, TS_{max}: 130 °C, TS_{min}: 2 °C. Fluid group 2, category 4§3 and category I + module A. Conformity assessment procedures according to directive 2014/68/EU, Annex III.

Products that fall under Article 4§3 shall not be CE-marked according to directive 2014/68/EU.

Battery Regulation (2023/1542). Embedded batteries fulfil the requirements of the Battery Regulation.

Notified body, Quality system ISO 9001: DNV, Tuborg Parkvej 8, 2., DK-2900 Hellerup.

Date: 2024-12-23, Skanderborg

Vice President, Quality & Sustainability:



Jens Hørdum

Note 1. The type number of the meter

The type number consists of two parts, a 9-digit static part and a 5-digit dynamic part. The static part of the type number is printed on the front of the meter, while the dynamic part of the type number can be viewed in the display.

To evoke the dynamic part of the type number, press the primary key and hold it down until the text 2 – TECH becomes visible in the display. Release the primary key briefly and subsequently use it to shift forward until index number 2-018-00 is visible in the display. Now use the secondary key to shift forward until index number 2-018-09 is visible in the display, release the key and the dynamic part of the type number will be visible in the display with reference N° 21 in the display's upper right corner.



Primary key



Secondary key

Note: In the event of inconsistency or discrepancy between the English version and any other language version, the English version shall prevail.

No.: FILE100000363_C



EU DECLARATION OF CONFORMITY

Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
T: +45 89 93 10 00
F: +45 89 93 10 01
M: kamstrup@kamstrup.com

We, Kamstrup A/S declare that this Declaration is issued under our sole responsibility and belongs to the following product: **Kamstrup Pt500 Temperature Sensors** type number 65-00-0xx-xxx or 66-00-0xx-xxx or 65-56-4xx-xxx, serial number 2025/XXXXXXXX, which is in conformity with the relevant European Directives, including all consolidated versions, as marked below:

RoHS (2011/65/EU), standard: EN/IEC 63000:2018.

MID (2014/32/EU), standards: EN 1434:2007/AC:2007, EN 1434:2015. Applies for products marked with CE marking and supplementary metrology marking according to Article 21 in directive 2014/32/EU.

Module B certificate number: DK-0200-MI004-036.

Notified Body, Module D certificate: FORCE Certification A/S, EU Notified Body number 0200, Park Allé 345, DK-2605 Brøndby. Module D certificate number: DK-0200-MID-D-001.

Date: 2024-12-23, Skanderborg

Vice President, Quality & Sustainability:



Jens Hørdrum

Note: In the event of inconsistency or discrepancy between the English version and any other language version, the English version shall prevail.

No.: FILE100001696_C

kamstrup

EU DECLARATION OF CONFORMITY

Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
T: +45 89 93 10 00
F: +45 89 93 10 01
M: kamstrup@kamstrup.com

We, Kamstrup A/S declare that this Declaration is issued under our sole responsibility and belongs to the following product: **Kamstrup TemperatureSensor 63 / Kamstrup TemperatureSensor 83**, type number 61-63-D0-0XX-XXX or type number 61-83-D0-0XX-XXX, serial number 2025/XXXXXXXX, which is in conformity with the relevant European Directives, including all consolidated versions, as marked below:

RoHS (2011/65/EU), standard: EN/IEC 63000:2018.

MID (2014/32/EU), standards: EN 1434:2007, EN 1434:2015/A1:2018, EN 1434:2022.

Applies for products marked with CE marking and supplementary metrology marking according to Article 21 in directive 2014/32/EU.

Module B certificate number: DK-0200-MI004-046.

Notified Body, Module D certificate: FORCE Certification A/S, EU Notified Body number 0200, Park Allé 345, DK-2605 Brøndby. Module D certificate number: DK-0200-MID-D-001.

Date: 2024-12-23, Skanderborg

Vice President, Quality & Sustainability:



Jens Hørdum

Note: In the event of inconsistency or discrepancy between the English version and any other language version, the English version shall prevail.

No.: FILE100000368_C

kamstrup

EU DECLARATION OF CONFORMITY

Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
T: +45 89 93 10 00
F: +45 89 93 10 01
M: kamstrup@kamstrup.com

We, Kamstrup A/S declare that this Declaration is issued under our sole responsibility and belongs to the following product: **Kamstrup Temperature Sensors**, type number 61-x3-Ex-xxx-xxx or 61-x3-Gx-xxx-xxx, serial number XXXXXXXXXXXXX, which is in conformity with the relevant European Directives, including all consolidated version, as marked below:

RoHS (2011/65/EU), standard: EN/IEC 63000:2018.

MID (2014/32/EU)

Applies for products marked with CE marking and supplementary metrology marking according to Article 21 in directive 2014/32/EU.

Module B certificate number: DE-16-MI004-PTB010 (standards: EN 1434:2007/AC:2007, EN 1434:2015) or DE-17-MI004-PTB004 (standards: EN 1434:2007/AC:2007, EN 1434:2015) or A0445/2553/2016 (standard EN 1434:2007/AC:2007).

Notified Body, Module D certificate: FORCE Certification A/S, EU Notified Body number 0200, Park Allé 345, DK-2605 Brøndby. Module D certificate number: DK-0200-MID-D-001.

Date: 2024-12-23, Skanderborg

Vice President, Quality & Sustainability:



Jens Hørdum